

City of Galion Weekly Reports
Week of October 31, 2016

Water Treatment Plant/ Waste Water Treatment Plant

Issues for immediate attention:

- Ongoing harmful algae bloom (HAB) sampling
- Clean aluminum sulfate tanks, empty remaining contaminated chemical

This Week:

- Pool is winterized
- WTP operations
- HAB sample sent to EPA lab
- Worked with distribution for sampling and flushing new line in Crew Avenue area
- WWTP operations and maintenance

Next Week:

- Finish winterizing splash park
- Send HAB sample to Alloway lab
- WTP maintenance and operations
- WWTP operations and maintenance
- Check lifts for proper operations
- Repair sludge dryer
- Refill aluminum sulfate tanks

Long-term Activities:

- Itemize repair and replacement of pool equipment and building
- Replace filter sand
- Continue sampling and plant repairs as needed
- Finish HAB sampling
- High service pump repaired
- Get VFD for second raw water pump
- Backup power supply and screw pump replacement
- Design back up sludge discharge system