

## City of Galion Weekly Report Week of November 14, 2016

### **Service Department**

This week: OUPS locates, winterization of park restrooms, leaf pick up

Next week: Street sweeping and leaf pickup

Long-term activities: Rebuild softball fields at PECO, set poles and cable to protect Amick grass areas and Disc Golf Course (winter project), Depot pavilion site prep

### **Water Treatment Plant/Waste Water Treatment Plant**

Issues for immediate attention:

- WTP operations and maintenance
- Ongoing harmful algae bloom (HAB) sampling
- Issues with high service pumps
- Processing sludge at WWTP
- Refill clarifier
- Control screen failure on bar screen

This week: Splash park winterized, cleaned WTP slaker, got an update on high service pumps status, sludge processing, drained and cleaned clarifier, secure HTI lift station access opening

Next week: Plant maintenance and operations, send water sample to EPA lab, check lifts for proper operations

Long-term projects:

- Itemize repair and replacement of pool equipment and building
- Replace filter sand
- Continue sampling and plant repair as needed
- Notified we have to HAB sampling through the winter
- VFD for second raw water pump
- High service pump repair
- WWTP backup power supply and screw pump replacement
- Design back up sludge discharge system